

# EC-TYPE EXAMINATION CERTIFICATE

Application of: Council Directive 96/98/EC of 20 December 1996 on Marine Equipment as amended by directive 2014/93/EU, issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Directorate. This Certificate is issued by DNV GL AS under the authority of the Government of the Kingdom of Norway.

## This is to certify:

**That the Surface materials and floor coverings with low flame-spread characteristics: paint systems**


with type designation(s)  
**Coltech M2**

Issued to  
**COLTECH LTD.**  
**Viotia, Greece**

is found to comply with the requirements in the following Regulations/Standards:  
**Annex A.1, item No. A.1/3.18b and Annex B, Module B in the Directive. SOLAS 74, Reg. II-2/3, II-2/5, II-2/6, II-2/9 & X/3, IMO MSC/Circ. 1120, 2000 HSC Code 7 and IMO 2010 FTP Code**

Further details of the equipment and conditions for certification are given overleaf.

**Høvik,**  
for **DNV GL AS**



This Certificate is valid until

Notified Body No.: **0575**

-----  
**Vidar Dolonen**  
**Head of Department**

DNV GL local office:  
**Piraeus**

-----  
**Martin Gjelstad**  
**Surveyor**



The Certificate is subject to terms and conditions overleaf. Any significant changes in design or construction of the product, or amendments to the Directive or Standards referenced above may render this Certificate invalid. The product liability rests with the manufacturer or his representative in accordance with Council Directive 96/98/EC, as amended. The Mark of Conformity may only be affixed to the product and a Declaration of Conformity may only be issued when the production/product assessment module referred to in the council directive, is fully complied with.

## Product description

"Coltech M2"

Is a solvent free epoxy primer.

Maximum dry film thickness: 200 µm.

## Application/Limitation

Approved for use as low flame spread material, not generating excessive quantities of smoke nor toxic products in fire.

Maximum organic content: 100% per dry film.

Approved colour: transparent.

Approved for use on metallic surface with thickness of at least 0.200 mm.

Approved for use throughout the accommodation.

The product satisfies the requirement for maximum calorific value (ref. Solas Chapter II-2, Reg 5.3.2.2) without further testing.

Each product is to be supplied with its manual for installation, use and maintenance.

## Type Examination documentation

Test report no. VTT-S-3087-15 dated 2015-06-23 from VTT Expert Service LTD, Espoo, Finland.

## Tests carried out

Tested according to IMO 2010 FTP Code part 5 and Annex 2 item 2.2 and 2.3.

## Marking of product

The product or packing is to be marked with name of manufacturer, type designation, fire-technical rating, MED Mark of Conformity and USCG approval number if applicable (see below).

## Mark of Conformity

The manufacturer is allowed to affix the Mark of Conformity according to Article 11 in the Council Directive 96/98/EC on Marine Equipment and shall issue a Declaration of Conformity, only when the module D or E or F of Annex B in the same directive is fully complied with.

Module D: The quality system for production and testing shall be approved by the Notified Body.

Module E: The quality system for inspection and testing shall be approved by the Notified Body.

Module F: Compliance of the products to type as described in this EC Type-Examination Certificate must be verified by the Notified Body who also shall issue a Certificate of Conformity.

## USCG Approval

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the "Agreement between the United States of America and the EEA EFTA states on the mutual recognition of Certificates of Conformity for Marine Equipment" signed 17 October 2005.